


NOTES:

- ALL PRODUCTS AND MATERIALS TO BE UTILISED DURING CONSTRUCTION TO COMPLY WITH EIRGRID FUNCTIONAL SPECIFICATION, ESNB STANDARDS, TII SPECIFICATION FOR ROAD WORKS AND ALL RELEVANT IRISH (EUROPEAN) AND BRITISH STANDARDS.
- 300mm MINIMUM VERTICAL AND HORIZONTAL CLEARANCES TO BE OBSERVED BETWEEN CABLE DUCTS AND THIRD PARTY SERVICES (e.g. GAS PIPES, WATER MAINS, CULVERTS, etc.) IN THE CASE OF HIGH RISK 3rd PARTY SERVICES, GREATER CLEARANCES MAY BE REQUIRED. DESIGNER TO CONSULT EIRGRID AND 3rd PARTY SERVICE OWNERS FOR GUIDANCE.
- STEEL PLATES MUST COVER DUCTS. NO OVERLAP IS REQUIRED HOWEVER STANDARD DIMENSIONS MAY RESULT IN AN OVERLAP. SPACING OF 10mm TO BE MAINTAINED BETWEEN STEEL PLATES TO PREVENT THE TRANSFER OF STRAY CURRENT.
- THE MINIMUM CLEARANCE BETWEEN ALL HV AND COMMUNICATION DUCTS IS **75mm**, BUT INCREASED SPACING MAY BE REQUIRED IN ORDER TO ACHIEVE THE CABLE RATING (TO BE CONFIRMED BY DESIGNER CABLE RATING CALCULATIONS).
- DRAWING IS INDICATIVE ONLY, TO BE USED TO AID IN THE DESIGN OF THE RELEVANT INFRASTRUCTURE.
- TEMPLATES ARE TO BE USED AT 5m INTERVALS DURING DUCT INSTALLATION IN CBGM. PRE-MADE 75mm WIDE CONCRETE SPACERS TO BE USED DURING DUCT INSTALLATION IN WET CONCRETE.
- MINIMUM BURIAL DEPTH IS **450mm**.
- HAND DIG WITHIN 500mm OF EXISTING SERVICE.
- WHERE AN EARTH CONTINUITY CONDUCTOR (ECC) IS REQUIRED, A MIN 63mm DUCT TO BE INSTALLED OUTSIDE OF PHASE DUCT.

- RED MARKER STRIP
- YELLOW MARKER WARNING TAPE
- EXISTING SERVICE MARKER STRIP
- 6mm GALVANISED STEEL PLATE
- RAPID HARDENING WET CONCRETE C25/30
- CBGM B (CL. 822), COMPACTED TO CL. 813.10
- BACKFILL, COMPACTED (CL. 804)
- EXISTING GROUND


FULL FLAT FORMATION – REDUCED DEPTH FOR CROSSING OVER 3RD PARTY SERVICE



A= 125mm O.D. HDPE DUCT FOR COMMUNICATIONS
D= 160mm O.D. HDPE DUCT FOR HV CABLE
C= 63mm O.D. HDPE DUCT FOR EARTH CONTINUITY CONDUCTOR

* 5x200mm STEEL PLATES AND RED MARKER WHERE AND ECC IS NOT REQUIRED
** MIN 1225mm WHERE ECC NOT REQUIRED
*** SEE NOTE 9

00	FIRST ISSUE	DA	DG	CF	09/03/2020
REV	DESC	DRAWN	CHECKED	APPROVED	DATE

 EirGrid plc The Oval, 160 Shelbourne Road, Ballsbridge, Dublin 4, Ireland Telephone: +353 1 677 1700 Fax: +353 1 661 5375 Email: info@eirgrid.com Web: www.eirgrid.com		STANDARD 110kV CABLE DRAWINGS	
COPYRIGHT © EirGrid plc All rights reserved. No part of this work may be modified or reproduced or copied in any form or by any means – graphic, electronic or mechanical, including photocopying, recording, taping or information and retrieval system, or used for any purpose other than its designated purpose, without the written permission of EirGrid plc		DRAWING TITLE STANDARD 3rd PARTY CROSSING ABOVE IN FULL FLAT FORMATION 160mm HV DUCTS	
No of Shts 3	SIZE A3	SCALE N/A	
DRAWING NUMBER XDC-CBL-STND-H-002		SHEET 002	REV 00